

TOWN OF GLASTONBURY
GL-2015-14
NEW TOWN FACILITIES AND MAINTENANCE BARN
ADDENDUM NO. 3
NOVEMBER 10, 2014

Bid Due Date: 11/12/14 @ 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

Question 1: *The drawings indicate a fire water service to the building but no sprinkler system. Are we to assume the service terminates in the utility closet with a flanged end just above the finished floor?*

Answer: Yes on the flanged termination of sprinkler pipe in building.

Question 2: *Would the Town entertain a prefabricated wood framing system certified by an engineer registered in the State of Connecticut that would incorporate the specified exterior finishes?*

Answer: Yes, as a voluntary alternate, but the bidder has to acknowledge the original bid. All proposed alternates must have supporting data provided with the bid.

Question 3: *If the answer is no to item number two, would you entertain a voluntary alternate for the same?*

Answer: The voluntary option is OK. You would still need to acknowledge the actual bid.

Question 4: *Are the soffits to be made of PVC?*

Answer: Yes, the soffit and all trim boards are painted PVC.

END OF TEXT