

TOWN OF GLASTONBURY
GL-2017-26
LOCKER ROOM RENOVATION GLASTONBURY PD
ADDENDUM NO. 3
May 10, 2017

Bid Due Date: 05-11-17 @ 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum on the Bid Proposal Page (BP-1).

Question 1: "The trim piece will be supplied by the G.C. The trim piece will be painted to match the locker color." Can you provide detail drawings and specifications on the trim piece? ?

Answer: The trim piece is 1" X 1 ½ " 0.188" extruded aluminum angle closure strip painted to match locker color. .

Note: This addendum consists of 1 page including the above text.