

**TOWN OF GLASTONBURY
GL-2018-09
HEBRON AVENUE (RTE. 94) FENCE REPLACEMENT
LOCATED ALONG THE EXISTING MULTI USE TRAIL**

**ADDENDUM NO. 2
OCTOBER 11, 2017**

REVISED BID DUE DATE: OCTOBER 19, 2017 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

Make the following modifications to the Contract Documents:

SPECIAL PROVISIONS:

Delete paragraph 1 and 2 of the Materials Section of Special Provision Item # 0906216A- Pressure Treated Post and Board Fence located on page SP-4:

WOOD TREATMENT: Shall comply with American Wood Preservers Association (AWPA) standards for wood preservative treatment scheduled, FS TT-W-550 Wood Preservative – Chromated Copper Arsenate, and FS TT-W-571 Wood Preservative – Treating Practices. The treating plant shall imprint legible symbols in the end of all timber treated, indicating the name of the treating company and the type and year of treatment in accordance with AWPA Standards M1 and M6.

POSTS AND RAILS: Shall be Dimensional Lumber, No. 2 or better Southern Yellow Pine timbers. Pressure impregnated with waterborne CCA preservative. Treat to a minimum retention of .40 lbs per cubic foot. Lumber shall be properly seasoned when dressed and at time of treatment to 20% maximum moisture content. Air or kiln dry after treatment.

Replace paragraph 1 and 2 of the Materials Section of Special Provision Item # 0906216A- Pressure Treated Post and Board Fence located on page SP-4 with the following:

WOOD TREATMENT: Shall comply with American Wood Preservers Association (AWPA) standards for category UC4B- Ground Contact (Heavy Duty). The treating plant shall imprint legible symbols in the end of all timber treated, indicating the name of the treating company and the type and year of treatment in accordance with current AWPA Standards.

POSTS AND RAILS: Shall be Dimensional Lumber, No. 2 or better Southern Yellow Pine timbers. Pressure impregnated with ACQ preservative. Treat to a minimum retention of .60 lbs per cubic foot. Lumber shall be properly seasoned when dressed and at time of treatment to 20% maximum moisture content. Air or kiln dry after treatment.

END OF ADDENDUM NO. 2