

TOWN OF GLASTONBURY
GL-2018-13
ELECTRICAL UPGRADES AT FOUR ELEMENTARY SCHOOLS
ADDENDUM NO. 1
January 29, 2018

Bid Due Date: 02-06-18 @ 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum on the Bid Proposal Page (BP-1).

GENERAL INFORMATION

1. Contact Al Costa or Mike Fazzino at 860.652.7992 for access to schools.

ELECTRICAL DRAWINGS

1. Drawings All – **Revise** all Panel Boards from Main Circuit Breaker type to Main Lug Only type and A.I.C rating from 22K to 65K.
2. Drawings E1.2, E2.3, E3.3, E4.2 – **Revise** all feeder schedules from wire type THHN-2 to read XHHW-2.
3. Drawing E1.1 – Buttonball Elementary School Section A Electrical New Work Plan – **Revise** panel PAC-1 from surface mounted to flush mounted.
4. Drawing E1.2 – Buttonball Elementary School Section B Electrical New Work Plan – **Revise** Feeder Schedule feeder size for symbol F3 to read as follows: 4 X #2 XHHW-2 and 1 X #8 XHHW-2 GND in 1 ½”C.
5. Drawing E2.1 – Hebron Elementary School Section A Electrical New Work Plan – **Revise** panel PAC-1 from surface mounted to flush mounted.
6. Drawing E2.3 – Hebron Elementary School Section B Electrical New Work Plan – **Revise** Feeder Schedule feeder size for symbol F1 to read as follows: 2 – 3”C. with 4 X #400kcmil XHHW-2 and 1 X #1 XHHW-2 GND in each.
7. Drawing E4.2 – Naubuc Elementary School Section A Electrical New Work Plan – **Revise** panel PAC-1 from surface mounted to flush mounted.

ELECTRICAL SPECIFICATIONS

1. Specification Section - 26 20 00 part 2 – 2.1 – A. - **Revise** to read as follows: Panelboards shall be furnished in G.E. manufacture.

Note: This addendum consists of 1 page including the above text.