

**TOWN OF GLASTONBURY**  
**GL-2018-13**  
**ELECTRICAL UPGRADES AT FOUR ELEMENTARY SCHOOLS**  
**ADDENDUM NO. 2**  
February 2, 2018

Bid Due Date: 02-06-18 @ 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum on the Bid Proposal Page (BP-1).

**ELECTRICAL DRAWINGS**

1. Drawings All – **Clarification** from Addendum #1, all Panel Boards A.I.C rating shall be Series Rated at 65K.

**ELECTRICAL SPECIFICATIONS**

1. Specification Section - 26 20 00 part 2 – 2.1 – A. – **Clarification:** Panel boards shall only be furnished by G.E. manufacture.
2. Specification Section - 26 20 00 part 2 – 2.1 – D. - **Revise** to read as follows: All circuit breakers shall be ‘HCAR’ rated.

**Note: This addendum consists of 1 page including the above text.**