

# LONG-TERM STORMWATER MAINTENANCE SCHEDULE

TO BE COMPLETED TWO TIMES PER YEAR, ONCE IN SPRING (NOT LATER THAN APRIL 30) AND ONCE IN FALL (NO LATER THAN OCTOBER 30). THE MAINTENANCE ACTIONS SHALL TAKE PLACE A MINIMUM OF 48 HOURS AFTER ANY RAINFALL.

## LOCATION

## ACTION

STREETS AND  
PARKING LOTS

SWEEP USING TANDEM OR REGENERATIVE-AIR TYPE SWEEPER.

NOTE: IF DE-ICING AGENT OR OTHER ALTERNATIVE TO CONVENTIONAL SAND AND SALT APPLICATION IS USED, NEED FOR STREET SWEEPING MAY BE REDUCED OR ELIMINATED.

CATCH BASINS

CLEAR DEBRIS FROM GRATES.

CLEAN SUMPS WHEN THEY ARE MORE THAN 1/2 FULL.

SEDIMENTATION  
STRUCTURE

INSPECT FOR ACCUMULATION OF SEDIMENT AND FLOATING DEBRIS.

CLEAN CHAMBER WHEN SUMP IS MORE THAN 1/2 FULL.

STORMWATER  
TREATMENT BASINS

VERIFY THAT OUTLET STRUCTURES ARE NOT OBSTRUCTED. CLEAR DEBRIS FROM GRATES.

VERIFY THAT POND WATER LEVELS ARE NORMAL.

INSPECT FOR SEDIMENT ACCUMULATION AND REMOVE AS NECESSARY.

VERIFY THAT STABILIZATION MEASURES (RIP RAP ETC.) ARE IN PLACE.

MAKE REPAIRS AS REQUIRED.

UNDERGROUND  
INFILTRATION  
SYSTEM

INSPECT FOR ACCUMULATION OF SEDIMENT AND FLOATING DEBRIS IN ISOLATOR ROWS.

CLEAN CHAMBERS AS REQUIRED.

OUTLET  
PROTECTION  
INCLUDES RIP RAP  
APRONS AND LEVEL  
SPREADERS

VERIFY THAT OUTLETS ARE NOT OBSTRUCTED. CLEAR AS REQUIRED.

INSPECT FOR SEDIMENT ACCUMULATION AND REMOVE AS NECESSARY.

VERIFY THAT RIP RAP APRONS ARE IN PLACE.

MAKE REPAIRS AS REQUIRED.