

# TOWN OF GLASTONBURY

**BID #GL-2010-10**

**Glastonbury High School  
Emergency Power System  
GLASTONBURY, CT 06033**

**ADDENDUM #1**

**Dated: 11/6/2009**

**Bid due date 11/17/2009**

**11:00 a.m.**

Please be advised that the following addendum has been provided to all bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated October, 2009. Bidders are advised they should acknowledge receipt of this Addendum in the space provided on the Bid Form.

This Addendum consists of two (2) pages and the following documents:

1. High School Calendar
2. SK E102.1 – Changes related to existing gym feeder affecting Base Bid #3.
3. SK E102.2 – Changes to riser diagram related to existing gym feeder and clarification of Base Bid #3.
4. SK E103.1 - Changes related to existing gym feeder affecting Base Bid #4.
5. SK E103.2 – Changes to riser diagram related to existing gym feeder.

## **QUESTION AND ANSWERS**

1. Question: Provide clarification on riser diagram for bid #2 and #3.  
Answer: Clarification provide in attached sketch SK-E102.2.
2. Question: Provide clarification on fuel tank size for generators.  
Answer: The sub base tank for the 50 kw generator shall be sized to provide a minimum of twenty four hours of run time at full load. The sub base tank for the 200 and 350 kw generators shall be a minimum of 300 gallons.

3. Question: Provide clarification on fuel supply pumps for generators.  
 Answer: A return fuel pump for overflow (partial day tank kit) is required for the 200 and 350 kw generators. The fuel supplied to the sub base tank will be as shown in detail E2 on drawing E-102.
  
4. Question: Can a school calendar be provided?  
 Answer: Calendar is attached to this addendum. Note that dates are subject to change based on educational program changes, weather, etc.

**CHANGES/CLARIFICATIONS**

1. All additional clarifying questions shall be submitted, in writing, no later than 4:30 pm on November 12, 2009.
2. All questions shall be addressed to Herb Schwind at [herb.schwind@glastonbury-ct.gov](mailto:herb.schwind@glastonbury-ct.gov)
3. The site will be available for review on Tuesday, November 10, 2009 from 1:00 pm to 3:00 pm. Those interested in taking advantage of this additional site visit opportunity are required to sign in at the Community Use office of the GHS. Any questions raised shall be submitted, in writing, as directed in items #1 and #2 above.
4. Specification Sections 16495 & 16612 paragraphs 2.1 E – Delete this line
5. Add to Specification Sections 16495 & 16612 paragraphs 2.1 E – “Generac”
6. Add to Specification Sections 16495 & 16612 paragraphs 2.1 F – “No substitutes”.
7. It was determined that the feeders to the gym loads exit the electrical room underground in the pull section of the switchgear. Attached sketches SK-E102.1, SK-E102.2, SK-E103.1 & SK-E103.2 show the changes in scope or work required for interrupting this feeder and feeding it through the manual transfer switch.

END OF ADDENDUM NO. 1

**BID DUE DATE REMAINS UNCHANGED**

**Please confirm receipt of this addendum via fax by 11/09/09 by 4:00 PM to:  
 Kathy Hughey @ (860) 652-7590 (fax)**

Company Name: \_\_\_\_\_

Name of Person Responding: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

Kathy Hughey’s Phone (860) 652-7588