TOWN OF GLASTONBURY BID NO. GL-2023-35

STORM DRAINAGE AND CATCH BASIN REHABILITATION VARIOUS TOWN ROADS

ADDENDUM NO. 1 MAY 22, 2023

BID DUE DATE: MAY 31, 2023 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

QUESTIONS AND ANSWERS

Question 1: Please clarify the maximum required depth of catch basin rebuilding under

this contract.

Answer: Rebulding of catch basins is covered under the Item "Reset (Type) Catch Basin"

included in the Bid proposal which is described in Section 5.86 Catch Basins, Manholes, and Drop Inlets of the CONNDOT Form 818. As described in the Form 818 on page 237, this item includes reconstruction of a catch basin up to 3 feet measured vertically. Any reconstruction greater than 3 feet will be measured

and paid for as extra work.

Question 2: Is there any information regarding the depth of the pipe to be replaced?

Answer: Approximate depth to flow line is provided in the updated table included in

Section 1.03 of the Special Conditions as described below.

Make the following modifications to the Contract Documents:

SPECIAL CONDITIONS SECTION 1.03

The table describing storm drainage pipe replacement locations provided in this section on pages SC-1 and SC-2 is hereby replaced with the following table in order to provide additional information regarding approximate pipe depths to flowlines.

BID PROPOSAL FORM:

The bid proposal form is hereby replaced with the attached for inclusion of Item 0751711A 6" UNDERDRAIN. ALL BIDDERS <u>MUST</u> USE THE REVISED BID PROPOSAL FORM.

SPECIAL PROVISIONS:

The following Special Provision is <u>hereby added</u> to the contract: **ITEM 0751711A 6" UNDERDRAIN**

Note: This addendum consists of 7 pages including the above text.

STORM DRAINAGE AND CATCH BASIN REHABILITATION LOCATED ON VARIOUS TOWN ROADS BID PROPOSAL- REVISED

BID #GL-2023-35 ADDENDUM #1

TOWN OF GLASTONBURY					
BID / PROPOSAL		GL # 2023-35			
DATE ADVERTISED	MAY 1	0, 2023	DATE / TIME D	UE	MAY 31, 2023
					at
					11:00 A.M.
NAME OF PROJECT	STOR	STORM DRAINAGE AND CATCH BASIN REHABILITION			

IT IS THE RESPONSIBILITY OF THE BIDDER TO CHECK THE TOWN'S WEBSITE BEFORE SUBMITTING BID FOR ADDENDA POSTED PRIOR TO BID OPENING.

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDA. AS REQUIRED:
Addendum #1 (initial/date) Addendum #2 (initial/date) Addendum #3 (initial/date)
OTHER ITEMS REQUIRED WITH SUBMISSION OF BID PROPOSAL:
The following bid checklist describes items required for inclusion with the above-referenced bid proposal package. It is provided for the convenience of the bidders and, therefore, should not be assumed to be a complete list.
1. Included a copy of the Bid Bond as per Section 9 of the Information for Bidders. Original Bond to be mailed as specified herein.
2. Included Disclosure of Past and Pending Mediation, Arbitration, and Litigation cases against the Bidder or its Principals as per Section 16 of the Information for Bidders.
3. Included Qualifications Statement as per Section 19 of the Information for Bidders.
4. Provided certification for Compliance with Town Ordinance Prohibiting Natural Gas Waste & Oil Waste From Natural Gas Extraction Activities or Oil Extraction Activities as per Section 20 of the Information for Bidders
5. Checked Town web site for Addenda and acknowledged Addenda on page BP-1.
6. Acknowledged Code of Ethics on page BP-5.
7. Prepared ONE consolidated pdf file for on-line bid submission.
BIDDER NAME:

BIDDER NAME:

LINE <u>NO</u> .	ITEM NO.		TEM DESCRIPTION	<u>UNIT</u>	<u>QTY</u>	UNIT PRICE	<u>EXT</u>
1	0406002	Α	Temporary Pavement	SY	238		
2	0586601		Reset Type "C" Catch Basin	EA	74		
3	0586603		Reset Type "C" Catch Basin Double Grate Type 1	EA	1		
4	0586620		Reset Type "C-L" Catch Basin	EA	10		
5	0586750		Type "C" Catch Basin Top	EA	74		
6	0586751		Type "C" Catch Basin Top Double Grate Type 1	EA	1		
7	0586760		Type "C-L" Catch Basin Top	EA	10		
8	0686000.15		15" R.C. Pipe- 0'-10' Deep	LF	364		
9	0686000.24		24" R.C. Pipe- 0'-10' Deep	LF	235		
10	0944000	Α	Furnish and Placing Topsoil	SY	389		
11	0950005	Α	Turf Establishment	SY	389		
12	0970007	Α	Trafficperson (Uniformed Flagger)	HR	480		
13	0971001	Α	Maintenance and Protection of Traffic	LS	1		
14	0975004		Mobilization and Project Closeout	LS	1		
15	0977001		Traffic Cone	EA	30		
16	0980020		Construction Surveying	LS	1		
17	1220013		Construction Signs- Bright Florescent Sheeting	SF	142		
18	0751711	Α	6" Underdrain	LF	245		

STORM DRAINAGE AND CATCH BASIN REHABILITATION BID PROPOSAL- REVISED

BID #GL-2023-35 ADDENDUM #1

BIDDE	R NAME:					
LINE <u>NO</u> .	ITEM NO.	ITEM DESCRIPTION	<u>UNIT</u>	<u>QTY</u>	UNIT <u>PRICE</u>	EXT
TOTAL	BID AMOUNT:			\$	(Numeric)	
WRITT	EN TOTAL BID	AMOUNT:				

Note:

In the event that the Town finds computational errors in a respondent's bid proposal, the bid total cost shall be recalculated by the town based on the **unit prices** contained in the bid proposal

BID ALTERNATES:

	ITEM DESCRIPTION	<u>UNIT</u>	QTY	UNIT <u>PRICE</u>	EXT.
ALT. 1:	15" High Density Polyethylene Pipe- 0'-10' Deep	LF	364		
ALT. 2:	24" High Density Polyethylene Pipe- 0'-10' Deep	LF	235		

Note: Bid alternatives 1 and 2 will replace line items 8 and 9 respectively if selected by the Town

STORM DRAINAGE AND CATCH BASIN REHABILITATION BID PROPOSAL- REVISED

Attest

BID #GL-2023-35 ADDENDUM #1

BIDDER NAME:	
CODE OF ETHICS: I/We have reviewed a copy of the Town of Consultant Acknowledgement Form if I/We a	Glastonbury's Code of Ethics and agree to submit a re selected. Yes No*
*Bidder is advised that effective August 1, 20 or proposal where the Bidder has not agreed	003, the Town of Glastonbury cannot consider any bid I to the above statement.
certifies as to their own organization that	ies, and in the case of a joint bid each party thereto this bid has been arrived at independently without as to any matter relating to this bid with any other
Respectfully submitted:	
Type or Print Name of Individual	Doing Business as (Trade Name)
Signature of Individual	Street Address
Title	City, State, Zip Code
Date	Telephone Number/Fax Number
E-Mail Address	SS# or TIN#
(Seal – If bid is by a Corporation)	

ITEM # 0751711A 6" UNDERDRAIN

Section 7.51.02- Materials shall be amended as follows:

- (1) **Pipe:** The pipe for underdrains and outlets shall be SDR 35 Perforated PVC or approved equal.
- (2) **Aggregates:** crushed stone aggregate required for filling the trench shall meet the requirements of M.01.02 Coarse Aggregates, Table M.01.02-2 No. 8 stone
- (4) **Geotextile:** Geotextile shall be as specified in M.08.01-19 Geotextiles and meet the requirements for subsurface drainage class A.

Section 7.51.03- Construction Methods shall be amended as follows:

6" Underdrain is required to be installed within the same trench, adjacent to the proposed storm drainage pipe replacement limits identified in the Addendum #1 revised Special Conditions- Section 01.03 Storm Drainage Pipe Replacement locations table. 6" Underdrain invert shall be installed at an elevation matching the adjacent storm drainage pipe at mid flow line and providing a minimum of 6" crushed stone envelope surrounding the underdrain wrapped in geotextile fabric.

SPECIAL CONDITIONS SECTION 01.03

STORM DRAINAGE PIPE REPLACEMENT LOCATIONS

	BEGIN CATCH BASIN LOCATION	END CATCH BASIN LOCATION	LENGTH OF PIPE	PIPE DIAMETER	APPROX. PIPE DEPTH TO FLOW LINE
CAVAN LANE	#210 CAVAN LANE	#213/#219 CAVAN LANE	24 L.F.	15"	3.0'±
CAVAN LANE	#240 CAVAN LANE	#237 CAVAN LANE	24 L.F.	15"	3.5'±
CAVAN LANE	#260 CAVAN LANE	#261 CAVAN LANE	24 L.F.	15"	4.5'±
CAVAN LANE	#291 CAVAN LANE	#279 CAVAN LANE	110 L.F.	24"	5.5'±
CAVAN LANE	#312 CAVAN LANE	#313 CAVAN LANE	24 L.F.	15"	4.0'±
*CAVAN LANE	#306 CAVAN LANE	#312 CAVAN LANE	125 L.F.	24"	5.0'±
CRESTDALE ROAD	#37 CRESTDALE ROAD	#38 CRESTDALE ROAD	24 L.F.	15"	5.5'±
CRESTDALE ROAD	#62 CRESTADLE ROAD	#71 CRESTDALE ROAD	24 L.F.	15"	6.0'±
*TARA DRIVE	#960 HEBRON AVENUE	#47 TARA DRIVE	120 L.F.	15"	4.5'±
TARA DRIVE	#19 TARA DRIVE	#27 TARA DRIVE	100 L.F.	15"	5.0'±

^{*}Bold Text = Storm Drainage Pipe Replacement requiring additional 6" Underdrain in trench.