

TOWN OF GLASTONBURY

BID #GL-2010-42

**Glastonbury Fire House #1
Boiler Replacement
Glastonbury, CT**

**ADDENDUM #1
Dated: April 20, 2010**

**Bid due date: April 28, 2010
11:00 a.m.**

This Addendum forms a part of the Contract Documents and modifies the original specifications and drawings dated April 6, 2010. Bidders are advised they should acknowledge receipt of this Addendum in the space provided on the Bid Form.

This Addendum consists of one (1) page:

ITEM AD1-1 SPECIFICATION PARAGRAPH 15010, 2.5 AND DRAWINGS M-2 AND E-1

QUESTION AND ANSWERS

1. Question: Please clarify the requirements for the motor starters.
Answer: **Clarification:** Motor starters for pumps HWP-1 and HWP-2 shall be automatic, full voltage magnetic starters with melting alloy type thermal overload protection and two (2) sets of auxiliary normally open and normally closed contacts. Thermal overload protection shall be provided in each ungrounded leg. Starters shall be inoperable if a thermal unit is removed. Provide starters with control power transformers of secondary voltage required for the control power circuitry. Provide control power transformers with primary and secondary fusing. Provide starters with hand-off automatic selector switches in the cover and red and green pilot lights. Motor starters are to be furnished and installed by the contractor. New disconnect switches for the pumps shall be provided and installed by the contractor.

END OF ADDENDUM NO. 1