

**TOWN OF GLASTONBURY
BID NO. GL-2024-02
MAIN STREET PAVEMENT REHABILITATION
NEW LONDON TURNPIKE TO RIPLEY ROAD**

**ADDENDUM NO. 2
NOVEMBER 29, 2023**

REVISED BID DUE DATE: DECEMBER 5, 2023 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

NOTIFICATION TO BIDDERS:

Please be advised that the Bid due date has been extended to:

December 5, 2023 at 11:00 A.M.

A new Zoom link for the bid opening will be uploaded on Monday December 4, 2023

Make the following modifications to the Contract Documents:

QUESTIONS AND ANSWERS

Q1-2:	The specification for Horizontal Directional Drilling – Conduits seems to refer to larger and more complex drilling equipment than appears necessary to extend new conduits through the existing tree pits. Please clarify if guidance systems, etc are required or if other trenchless methods of conduit installation would be acceptable such as pneumatic jacking of conduits. Also please clarify the limits of proposed directional drilling on the plans.
A1-2:	The intent of the Horizontal Directional Drilling – Conduits item is to extend conduits through the limits of the tree pits using a trenchless installation method that will minimize disruption to the existing tree root systems and can follow the required horizontal and vertical alignment depicted on the plans. As shown on sheet 21 only the tree pit areas need to be handled in this manner as the remainder of the conduit installation is proposed to be open trench. Jacking of conduits that meets the stated goals would be considered acceptable under this item.

NOTE: This Addendum consists of 1 page.