



## Memo

August 2, 2024

**To:** Suzanne Simone, Environmental Planner

**Fr:** Wendy S. Mis, Director of Health *WSM*

**Re:** 39 Saddle Ridge Road  
Site Development Plan

---

This office has received the site development plan by Dutton Associates LLC dated 6/14/24, last revised 7/25/24, for 39 Saddle Ridge Road.

Connecticut Public Health Code requires a separating distance based on horizontal measurements of fifty (50) feet between a septic system (primary and reserve) and an open watercourse. The submitted plan does not provide sufficient separating distance between the primary system and the watercourse.

As such, the submitted plan does not meet that criteria of the Technical Standards for Subsurface Sewage Disposal Systems of the State of Connecticut, and no approval can be forwarded for Commission consideration.