

**TOWN OF GLASTONBURY
 BID NO. GL-2011-11
 ASBESTOS REMOVAL AT VARIOUS SITES**

**ADDENDUM NO. 1
 OCTOBER 14, 2010**

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

Make the following modifications to the Contract Documents:

ITEM 1: 429 MARLBOROUGH ROAD LABORATORY STORAGE BUILDING

The quantity of floor tile mastic to be removed from this building is hereby revised as shown in the table below.

LABORATORY STORAGE BUILDING				
1-5	1x1 Floor Tile Mastic	Hallway #1, Main Room #1, Room #2, Offices 1-4, men's & women's bathrooms	3% Chrysotile 3% Total Asbestos	~2,600 SF

QUESTIONS AND ANSWERS

- Q1-1: The furniture and debris in various buildings will be in the way of the asbestos removal work. Will these items be removed by the Town or by the Contractor?
- A1-1: The Contractor will be responsible for relocating anything that is in the way of the asbestos removal work, including furniture or any other items or debris.
- Q2-1: Additional asbestos containing materials (ACM) appear to be visible in some rooms of the 429 Marlborough Road - Main Office Building above the ceiling. Should this material be included in the bid?
- A2-1: Since this material was not identified as ACM as part of the study it should not be included in the bid. At the time the work begins any additional suspected ACM should be brought to the attention of the Engineer, and the Town will review these items on a case by case basis for inclusion as a change order to the contract.

END OF ADDENDUM NO. 1