

**TOWN OF GLASTONBURY
BID GL-2013-16
Winter Hill Water Treatment**

Addendum #2

**Date of Addendum December 20, 2012
Bid Due Date: December 21, 2012 @ 11:00 a.m.**

Question – in section 2.1 CARBON TREATMENT SYSTEM:

- A. Provide Carbon system for polishing the water to be Culligan HE DF-21 or approved equal.

Is this the proper model number?

Answer – NO, Model number should be CF (not DF) for carbon as described in specification.

Bidders are reminded to acknowledge the addendum in the space provided on the BP-1 page.

END OF TEXT