

TOWN OF GLASTONBURY

BID #RPGL-2013-19

**WINTER HILL WATER TREATMENT
GLASTONBURY, CT 06033**

ADDENDUM #1

Dated: 03/25/13

Due Date: 3/28/13 @ 11:00 A.M.

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution, or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

Question #1: What gpm should the system be designed for?

Answer: System is to be designed for 10 (ten) gpm.

BID DUE DATE REMAINS UNCHANGED

END OF TEXT