

TOWN OF GLASTONBURY

GL-2013-33
REBID

(5) GLASTONBURY ELEMENTARY SCHOOLS
ELECTRICAL DISTRIBUTION IMPROVEMENTS

BUTTONBALL ELEMENTARY SCHOOL
EASTBURY ELEMENTARY SCHOOL
HEBRON AVENUE ELEMENTARY SCHOOL
HOPEWELL ELEMENTARY SCHOOL
NAUBUC ELEMENTARY SCHOOL

ADDENDUM #1
June 24, 2013

Bid Due Date: **06/25/2013 @ 11:00
A.M.**

The attention of bidders submitting proposals for the above-referenced project is called to the following Addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or other change, are all to be included in and form a part of the proposed Contract Documents for the work. Bidders shall acknowledge this Addendum in the Bid Proposal by inserting its number on Page BP-1.

SPECIFICATIONS:

ADD 1-1 Specification Paragraph 16060, 2.2 D: Clarification – Surface ½” EMT conduit is acceptable for exposed wiring run within Classrooms in lieu of the Wiremold raceway.

DRAWINGS:

ADD 1-2 Buttonball drawing E-4, Eastbury drawing E-3, Hebron drawing E-4, Hopewell drawing E-4, Naubuc drawing E-4: General Specification Notes #7, Clarification – Surface ½” EMT conduit is acceptable for exposed wiring run within Classrooms in lieu of the Wiremold raceway.

Note: This addendum consists of 1 page including the above text.

END OF TEXT

